

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE


No. Water Supply / 8049 / 2026

Dated: 8/3/2026

It is certified that an inspection team headed by pratik arvind nikam (Water Supply Officer) from Urun-Ishwarpur Nagarparishad, Urun-Ishwarpur inspected the ANNASAHEB DANGE INTERNATIONAL SCHOOL, ISLAMPUR. on 04/03/2026 and found that the ANNASAHEB DANGE INTERNATIONAL SCHOOL, ISLAMPUR. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.t. Govt.

The above is valid for a period of 1 year.



Signature with Seal: 

Name: Pratik Arvind Nikam

Designation: Water Supply Officer

Name & Address: Urun-Ishwarpur M.C.

To,

ANNASAHEB DANGE INTERNATIONAL SCHOOL, ISLAMPUR.



सुशीलानंद अग्री पॉलिक्लिनिक, इस्लामपूर



Registration No. : Govt. of Maharashtra /Agri Dept/J.D.A.Kolhapur/ 02 / 2022 – 2025

Lab. Ref. No. : Water/2025-26/143

Receipt No. 12905

Receipt Date : 28/02/2026

Client Name : **Annasaheb Dange International School**

Address : **Islampur**

Taluka : **Walwa**

District : **Sangli**

Sample Source : Treated Water Sample Taken and Supplied in the Laboratory by Client

Drinking Water Analysis Report

Category of Parameter	Sr. No.	Parameters Analyzed	Observations	Unit	Permissible Limits IS : 10500 (1991)	
Physical	01	Temperature	28.00	°C	--	
	02	Odour	Odourless	--	Odourless	
	03	Turbidity	1.00	NTU	< 5	
	04	Total Dissolved Solids	100.00	mg/lit	< 500	
Chemical	05	Reaction (pH)	7.39	-	6.50 – 8.50	
	06	Electrical Conductivity at 25°C	195.00	µmhos/cm	< 500	
	07	Calcium	10.00	mg/lit	< 75	
	08	Magnesium	4.80		< 30	
	09	Total Hardness	44.71		< 300	
	10	Total Alkalinity	61.00		< 200	
	11	Chlorides	62.04		< 250	
Biological	12	Most Probable Nos.	0		No/100 ml	Nil

Remark : The Physical, Chemical and Biological parameters of supplied water sample are within limits. The supplied sample is suitable for drinking purpose.

**Lab In-Charge
Sushilanand Agro Polyclinic**